



Beden Aluminium









Fenster · windows
 Rollläden · shutters
 Türen + Tore · doors
 Fassaden · curtain walling
 Baubeschläge · building hardware


TEST CERTIFICATE NO. 17/11-A005-Z1

Version 1.en

PFB-Internal-No. 18/01-A021

Initial type testing (ITT) of performance characteristics in accordance with EN 14351-1 :2006 + A1 : 2010 "Windows and doors - Product standard, performance characteristics - Part 1: Windows and external pedestrian doorsets without resistance to fire and/or smoke leakage characteristics – German version EN 14351-1:2006 + A2:2016"

Applicant IQ Aluminium Systems -Ege Profil Tic. ve San.A.Ş.
 Atatürk Plastik OSB Mah.5 Cad.4
 Menemen / Izmir
 Turkey



Product type Single casement sliding door with fixed side part
 AL, double glazing




Product name Renovatio Series

Hardware Sigenia-Aubi


Sealing EPDM

Dimension Total outside dimensions (W x H) max. 2200 mm x 2200 mm

Classification According to test report No. 17/11-A005-B1 of January 17, 2018:

	EN 1026	Air Permeability	EN 12207	Class 4
	EN 1027	Water tightness	EN 12208	Class E1050
	EN 12211	Resistance to wind load	EN 12210	Class C5/B5

Validity Period of validity of EN 14351-1 : 2006 + A2 : 2016


 Dipl.-Ing. (FH) Rüdiger Müller
 Head of Institute




 Yigit Altug
 Responsible Official



e

.

to

s

le

